



ALFA CHANNEL® STANDARD SPECIFICATION

Precast Trench Drain 4" ID with Solid Embossed Stainless Steel Cover

System ID#: 2446 / 2447

Trench drain shall be Alfa Channel®; By MultiDrain Systems, Inc., which is located at: 1405 Industrial Drive; Statesville, NC 28625; ASD. Toll Free Tel: 800-433-1119; Tel: 704-508-1010; Fax: 704-508-1011; Email: [request info \(steve.born@multidrain.com\)](mailto:steve.born@multidrain.com); Web: www.multidrain.com.

System Components:

Precast Trench Drain - The precast trench shall be manufactured using polyester polymer concrete with the following material properties when tested:

Property	Test Method	Value
Compressive Strength	ASTM C579	14,000 psi Minimum
Bending Strength	ASTM C580	4,000 psi Minimum
Tensile Strength	ASTM C307	2,000 psi Minimum
Moisture Absorption	ASTM D570	0.1% Maximum
Chemical Resistance	ASTM C267	Pass
Freeze/Thaw w/o weight loss	ASTM C666	1,600 Number of Cycles Minimum
Resistance to Fungi	ASTM G21	Zero (0) Rating Mold Growth
UL/ULC Listed- Flame Spread	UL-723	Class A

The trench consisting of 39.19" (1 meter) or 19.56" (1/2 meter) channels with nominal 6" (155mm) outside width, 4" (100mm) inside width. Pre-sloped channels shall have a standard slope of 0.6% with radius bottom. Non-sloping channels must have written approval by engineer prior to installation. Channels shall have tongue and groove joints. Grate lock down slots shall have polyethylene vibration dampening inserts. All channels must have full length anchoring ribs for a positive mechanical lock with the surrounding concrete.

Sidewall Extensions – Sidewall extensions for channels may be used for hydraulic performance or to maintain the standard slope of 0.6% in greater trench run lengths. Sidewall extensions shall be composed of similar material and thickness as the channels and shall have tongue and groove joints.

Solid Cover – Cover shall be MultiDrain part number 2446/2447. Covers are 39.19" (1 meter) and 19.6 (1/2 meter) respectively. Cover shall be a minimum of 14ga stamped embossed 18-8 stainless steel. Covers shall meet a minimum 75 psi proof load per AASHTO M-306 test modified by utilizing a 9" x 3" load plate. Covers shall seat into channels without rocking and shall be locked to the channel using a stainless steel 5/16 – 18 UNC bolt and stainless steel toggle bar system with a bolt torque of 3in/lb. Covers shall be made in U.S.A., and shall conform to the FHWA's "Buy America" policy 23 CFR 635.410(b) and Federal Acquisitions Regulations (FAR) 52.225 "Buy American Act".

Quality Assurance:

Submittals: A Certificate of Compliance in conformance with the provisions of these Standard Specifications shall be furnished to the Engineer. Grates shall be independently tested to AASHTO M-306.